TEST RESULTS OF STEEL

Lab ID	:	**CP-2017-08-01-01** **Date: 03-08-17**
Customer	:	Assistant Executive Engineer, Dasarahalli sub division, BBMP, Bangalore.
Address	:	Dasarahalli sub division, BBMP, Bangalore.
Project Name	:	Improvements & Construction of CC road from pampa Mahakavi Kuvempu road to Prashantha Nagara cross road in Dasarahalli in Ward No.15 Dasarahalli sub division.
Agency	:	Sri N.Shivananda, No.35, 2nd Cross, 1st A Main road, Defiance colony, Bagalagunte, Bangalore.
Customer's Reference	:	EE/DD/WO/97/17-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	01-08-17
Sample ID No	:	2017-08-01-01/01
Sample Type	:	SUNVIK
Reference to BIS codes	:	IS 1786-2008, IS:1608-2005(RA 2011), IS 1599-2012.
Date of test:	:	02-08-17

Sl.No	Identification of sample	Grade of the sample	Diameter of the steel bar	Weight of the sample	Yield stress	Tensile strength	Elongation	Bend test	Rebend test
			(mm)	(kg/m)	(N/mm2)	(N/mm2)	(%)		
1	SUNVIK	Fe550	10	0.616	572	650	19.5%	Satisfactory	Satisfactory

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರು
ಬಿ.ಡಿ.ಎ.ಸಹಕಾರಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

End of Report

TEST RESULTS OF STEEL

Lab ID	:	**CP-2017-08-09-01** **Date: 11-08-17**
Customer	:	Assistant Executive Engineer, Dasarahalli sub division, BBMP, Bangalore.
Address	:	Dasarahalli sub division, BBMP, Bangalore.
Project Name	:	Improvements & Construction of CC road from pampa Mahakavi Kuvempu road to Prashantha Nagara cross road in Dasarahalli in Ward No.15 Dasarahalli sub division.
Agency	:	Sri N.Shivananda, No.35, 2nd Cross, 1st A Main road, Defiance colony, Bagalagunte, Bangalore.
Customer's Reference	:	EE/DD/WO/97/17-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	09-08-17
Sample ID No	:	2017-08-09-01/01
Sample Type	:	SUNVIK
Reference to BIS codes	:	IS 1786-2008, IS:1608-2005(RA 2011), IS 1599-2012.
Date of test:	:	10-08-17

Sl.No	Identification of sample	Grade of the sample	Diameter of the steel bar	Weight of the sample	Yield stress	Tensile strength	Elongation	Bend test	Rebend test
			(mm)	(kg/m)	(N/mm2)	(N/mm2)	(%)		
1	SUNVIK	Fe550	10	0.615	578	654	20.0%	Satisfactory	Satisfactory

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

FOR CIVIL Pro.

CIVIL PRO Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

End of Report